

# 1788 Linking Device Specifications

Catalog Numbers 1788-EN2DNROM, 1788-EN2DNR, 1788-EN2FFR, 1788-EN2PAR, 1788-CN2DN, 1788-CN2FFR, 1788-CN2PAR, 1788-FBIB4R, 1788-FBIB6

Topic	Page
1788-EN2DNR and 1788-EN2DNROM EtherNet/IP to DeviceNet Linking Devices	2
1788-CN2DN ControlNet to DeviceNet Linking Device	5
Linking Devices to FOUNDATION Fieldbus Networks	8
FOUNDATION Fieldbus Junction Boxes	11
Linking Devices to Profibus PA Networks	14
Additional Resources	16



## 1788-EN2DNR and 1788-EN2DNROM EtherNet/IP to DeviceNet Linking Devices

The 1788-EN2DNR and 1788-EN2DNROM linking devices connect an EtherNet/IP network to a DeviceNet network.

### Technical Specifications - 1788-EN2DNR, 1788-EN2DNROM

Attribute	1788-EN2DNR	1788-EN2DNROM
Power requirements	Input: 24V DC, 150 mA, Class 2/SELV DeviceNet: 24V DC, 60 mA, Class 2/SELV	Logic power supply: 24V DC SELV/PELV (-15...20%), 100 mA max at 24V DC DeviceNet power supply: 24V DC SELV/PELV, 20 mA max at 24V DC
Isolation voltage	30V (continuous), basic insulation type, power to system, Ethernet to system, DeviceNet to system, and USB to system. Type tested at 500V AC for 60 s.	—
EtherNet/IP connection	RJ45 connector according to IEC 60603-7, 2 or 4 pair Category 5e minimum cable according to TIA 568-B.1 or Category 5 cable according to ISO/IEC 24702.	—
DeviceNet connection <sup>(1)</sup>	0.52 mm <sup>2</sup> (20 AWG), 1485C-P1-Cxxx.	—
Power connection	Power: 0.25...2.5 mm <sup>2</sup> (22...14 AWG) solid or stranded copper wire rated at 105 °C (221 °F), or greater, 1.2 mm (3/64 in.) insulation max.	—
Wiring category <sup>(2)</sup>	2 - on power ports 2 - on communication ports	3 - on USB ports 2 - on power ports 2 - on communications ports
Enclosure type rating	None (open-style)	Meets IP67 and NEMA 4/4X
North American temperature code	T4	—
ATEX temp code	T4	—
IEC temperature code	T4	—

(1) Refer to DeviceNet Media Design Installation Guide, publication [DNET-UM072](#).

(2) Use this Conductor Category information for planning conductor routing. Refer to Industrial Automation Wiring and Grounding Guidelines, publication [1770-4.1](#).

## Environmental Specifications - 1788-EN2DNR, 1788-EN2DROM

Attribute	1788-EN2DNR	1788-EN2DROM
Temperature, operating IEC 60068-2-1 (Test Ad, Operating Cold), IEC 60068-2-2 (Test Bd, Operating Dry Heat), IEC 60068-2-14 (Test Nb, Operating Thermal Shock)	-25...60 °C (-13...140 °F)	0...60 °C (32...140 °F)
Temperature, surrounding air, max.	60 °C (140 °F)	60 °C (140 °F)
Temperature, nonoperating IEC 60068-2-1 (Test Ab, Unpackaged Nonoperating Cold), IEC 60068-2-2 (Test Bb, Unpackaged Nonoperating Dry Heat), IEC 60068-2-14 (Test Na, Unpackaged Nonoperating Thermal Shock)	-40...85 °C (-40...185 °F)	-40...85 °C (-40...185 °F)
Relative humidity IEC 60068-2-30 (Test Db, Unpackaged Damp Heat)	5...95% noncondensing	5...95% noncondensing
Shock, operating IEC 60068-2-27 (Test Ea, Unpackaged Shock)	30 g	30 g
Shock, nonoperating IEC 60068-2-27 (Test Ea, Unpackaged Shock)	50 g	30 g
Vibration IEC 60068-2-6 (Test Fc, Operating)	2 g @ 10...500 Hz	2 g @ 10...500 Hz
Emissions IEC 61000-6-4	IEC 61000-6-4	IEC 61000-6-4
ESD Immunity IEC 61000-4-2	6 kV contact discharge 8 kV air discharge	6 kV contact discharge 8 kV air discharge
Conducted RF Immunity IEC 61000-4-6	10 V rms with 1 kHz sine-wave 80% AM from 150 kHz...80 MHz	10V rms with 1 kHz sine-wave 80% AM from 150 kHz...80 MHz
Radiated RF Immunity IEC 61000-4-3	10 V/m with 1 kHz sine-wave 80% AM from 80...1000 MHz and 1400...2000 MHz 10 V/m with 200 Hz 50% Pulse 100% AM @ 900 MHz 10 V/m with 200 Hz 50% Pulse 100% AM @ 1890 MHz 1 V/m with 1 kHz sine-wave 80% AM from 2000...2700 MHz	10V/m with 1 kHz sine-wave 80% AM from 80...2000 MHz 10V/m with 200 Hz 50% Pulse 100% AM at 900 MHz 10V/m with 200 Hz 50% Pulse 100% AM at 1890 MHz 10V/m with 1 kHz sine-wave 80% AM from 2000...2700 MHz
EFT/B Immunity IEC 61000-4-4	±3 kV at 5 kHz on power ports ±3 kV at 5 kHz on EtherNet/IP and DeviceNet ports	±3 kV at 5/100kHz on DC power ports ±3 kV at 5/100kHz on communication ports
Surge Transient Immunity IEC 61000-4-5	±500V line-line (DM) and ±1 kV line-earth (CM) on power ports ±2 kV line-earth (CM) on EtherNet/IP and DeviceNet ports	±500V line-line(DM) and ±1 kV line-earth(CM) on power ports ±2 kV line-earth(CM) on communications ports
Voltage variation IEC 61000-4-29	10 ms interruption on DC power port	10 ms interruption on DC power port

## Certifications - 1788-EN2DNR, 1788-EN2DR0M

Certification (when product is marked) <sup>(1)</sup>	1788-EN2DNR	1788-EN2DR0M
c-UL-us	UL Listed for Class I, Division 2 Group A,B,C,D Hazardous Locations, certified for U.S. and Canada. See UL File E194810.	UL Listed Industrial Control Equipment, certified for US and Canada. See UL File E65584.
CE	European Union 2004/108/EC EMC Directive, compliant with: <ul style="list-style-type: none"> <li>EN 61326-1: Meas./Control/Lab., Industrial Requirements</li> <li>EN 61000-6-2: Industrial Immunity</li> <li>EN 61000-6-4: Industrial Emissions</li> <li>EN 61131-2: Programmable Controllers (Clause 8, Zone A and B)</li> </ul> European Union 2011/65/EU RoHS, compliant with: <ul style="list-style-type: none"> <li>EN 50581; Technical Documentation</li> </ul>	
RCM	Australian Radiocommunications Act, compliant with: <ul style="list-style-type: none"> <li>EN 61000-6-4; Industrial Emissions</li> </ul>	
Ex	European Union 94/9/EC ATEX Directive, compliant with: <ul style="list-style-type: none"> <li>EN 60079-15; Potentially Explosive Atmospheres, Protection "n"</li> <li>EN 60079-0; General Requirements II 3 G Ex nA IICT4 Gc X</li> <li>DEMKO13ATEX1355620X</li> </ul>	—
KC	Korean Registration of Broadcasting and Communications Equipment, compliant with: <ul style="list-style-type: none"> <li>Article 58-2 of Radio Waves Act, Clause 3</li> </ul>	
EtherNet /IP	ODVA conformance tested to EtherNet/IP specifications.	
DeviceNet	ODVA conformance tested to DeviceNet specifications.	

(1) See the Product Certification link at <http://www.ab.com> for declarations of conformity, certificates, and other certification details.

## 1788-CN2DN ControlNet to DeviceNet Linking Device

The 1788-CN2DN linking device connects a ControlNet network to a DeviceNet network.

### Technical Specifications - 1788-CN2DN

Attribute	1788-CN2DN
Power requirements	Input: 24V DC, 500 mA DeviceNet: 24V DC, 90 mA, Class 2
Isolation voltage	30V (continuous), basic insulation type, between all ports. Type tested at 720V DC for 60 s.
ControlNet connection	RG6
DeviceNet connection <sup>(1)</sup>	0.52 mm <sup>2</sup> (20 AWG), 1485C-P1-Cxxx.
Power connection	Power: 0.25 . . . 2.5 mm <sup>2</sup> (22 . . . 14 AWG) solid or stranded copper wire rated at 75 °C (167 °F), or greater, 1.2 mm (3/64 in.) insulation max.
Wiring category <sup>(2)</sup>	3 - on power ports 2 - on communication ports
Dimensions (H x W x D), approx.	120 x 200 x 87 mm (4 11/16 x 7 7/8 x 3 7/16 in.)
Enclosure type rating	None (open-style)
North American temperature code	T4A
IEC temperature code	T4

(1) Refer to DeviceNet Media Design Installation Guide, publication [DNET-UM072](#).

(2) Use this Conductor Category information for planning conductor routing. Refer to Industrial Automation Wiring and Grounding Guidelines, publication [1770-4.1](#).

## Environmental Specifications - 1788-CN2DN

Attribute	1788-CN2DN
Temperature, operating IEC 60068-2-1 (Test Ad, Operating Cold), IEC 60068-2-2 (Test Bd, Operating Dry Heat), IEC 60068-2-14 (Test Nb, Operating Thermal Shock)	0...60 °C (32...140 °F)
Temperature, surrounding air, max.	60 °C (140 °F)
Temperature, nonoperating IEC 60068-2-1 (Test Ab, Unpackaged Nonoperating Cold), IEC 60068-2-2 (Test Bb, Unpackaged Nonoperating Dry Heat), IEC 60068-2-14 (Test Na, Unpackaged Nonoperating Thermal Shock)	-40...85 °C (-40...185 °F)
Relative humidity IEC 60068-2-30 (Test Db, Unpackaged Damp Heat)	5...95% noncondensing
Shock, operating IEC 60068-2-27 (Test Ea, Unpackaged Shock)	30 g
Shock, nonoperating IEC 60068-2-27 (Test Ea, Unpackaged Shock)	50 g
Vibration IEC 60068-2-6 (Test Fc, Operating)	2 g @ 10...500 Hz
Emissions CISPR 11 (IEC 61000-6-4)	Class A
ESD Immunity IEC 61000-4-2	6 kV contact discharge 8 kV air discharge
Conducted RF immunity IEC 61000-4-6	10 V rms with 1 kHz sine-wave 80% AM from 150 kHz...80 MHz
Radiated RF immunity IEC 61000-4-3	10 V/m with 1 kHz sine-wave 80% AM from 30...2000 MHz 10 V/m with 200 Hz 50% Pulse 100% AM @ 900 MHz 10 V/m with 200 Hz 50% Pulse 100% AM @ 1890 MHz 3 V/m with 1 kHz sine-wave 80% AM from 2000...2700 MHz
EFT/B immunity IEC 61000-4-4	±4 kV at 5 kHz on power ports ±3 kV at 5 kHz on communication ports
Surge Transient immunity IEC 61000-4-5	±2 kV line-earth (CM) on communication ports

## Certifications - 1788-CN2DN

Certification (when product is marked) <sup>(1)</sup>	1788-CN2DN
c-UL-us	UL Listed Industrial Control Equipment, certified for US and Canada. See UL File E65584. UL Listed for Class I, Division 2 Group A,B,C,D Hazardous Locations, certified for U.S. and Canada. See UL File E194810.
CSA	CSA Certified Process Control Equipment. See CSA File LR54689C. CSA Certified Process Control Equipment for Class I, Division 2 Group A,B,C,D Hazardous Locations. See CSA File LR69960C.
CE	European Union 2004/108/EC EMC Directive, compliant with: <ul style="list-style-type: none"> <li>• EN 61326-1: Meas./Control/Lab., Industrial Requirements</li> <li>• EN 61000-6-2: Industrial Immunity</li> <li>• EN 61000-6-4: Industrial Emissions</li> <li>• EN 61131-2: Programmable Controllers (Clause 8, Zone A and B)</li> </ul>
C-Tick	Australian Radiocommunications Act, compliant with: <ul style="list-style-type: none"> <li>• AS/NZS CISPR 11; Industrial Emissions</li> </ul>
Ex	European Union 94/9/EC ATEX Directive, compliant with: <ul style="list-style-type: none"> <li>• EN 60079-15; Potentially Explosive Atmospheres, Protection "n"</li> <li>• EN 60079-0; General Requirements I 3 G Ex nA IIC T4X Gc</li> </ul>
DeviceNet	ODVA conformance tested to DeviceNet specifications
CI	ControlNet Int'l conformance tested to ControlNet specifications.

(1) See the Product Certification link at <http://www.ab.com> for declarations of conformity, certificates, and other certification details.

## Linking Devices to FOUNDATION Fieldbus Networks

The 1788-EN2FFR linking device provides a gateway between EtherNet/IP and FOUNDATION Fieldbus networks.

The 1788-CN2FFR linking device provides a gateway between ControlNet and FOUNDATION Fieldbus networks.

### Technical Specifications - 1788-EN2FFR, 1788-CN2FFR

Attribute	1788-EN2FFR, 1788-CN2FFR
Power requirements	Input: 24...32V DC, 0.75 A, Class 2/SELV Foundation Fieldbus (FF): 0.5 A @24V DC single trunk; 0.4 A @ 24V DC dual trunk Power is connected to the linking device by using the 2-way Phoenix connector.
Power consumption	260 mA at 24 V (with no field devices attached)
Power dissipation	12.24 W at 24V DC
Isolation voltage	30V (continuous), basic insulation type, network channels to power, and network channels to network channels. No isolation between redundant network channels. Type tested at 500V DC for 60 s.
Ethernet conductors	CAT5 STP/UTP
Terminal torque	DC Power connections: 0.22...0.25 N•m (2...2.2 lb•in) Fieldbus connections: 0.5...0.6 N•m (4.4...5.3 lb•in)
Wire size	DC power and Foundation Fieldbus connections: 0.205...0.823 mm <sup>2</sup> (24...18 AWG) solid or stranded copper wire rated at 82 °C (180 °F) or greater 1.2 mm (3/64 in.) insulation max
Wiring category <sup>(1)</sup>	1 - on power ports 2 - on ControlNet, Ethernet, and Foundation Fieldbus ports
Enclosure type rating	None (open-style)
North American temperature code	T4
IEC temperature code	T4

(1) Use this Conductor Category information for planning conductor routing. Refer to Industrial Automation Wiring and Grounding Guidelines, publication [1770-4.1](#).



## Environmental Specifications - 1788-EN2FFR, 1788-CN2FFR

Attribute	1788-EN2FFR, 1788-CN2FFR
Temperature, operating IEC 60068-2-1 (Test Ad, Operating Cold), IEC 60068-2-2 (Test Bd, Operating Dry Heat), IEC 60068-2-14 (Test Nb, Operating Thermal Shock)	0...60 °C (32...140 °F)
Temperature, surrounding air, max.	60 °C (140 °F)
Temperature, nonoperating IEC 60068-2-1 (Test Ab, Unpackaged Nonoperating Cold), IEC 60068-2-2 (Test Bb, Unpackaged Nonoperating Dry Heat), IEC 60068-2-14 (Test Na, Unpackaged Nonoperating Thermal Shock)	0...60 °C (32...140 °F)
Relative humidity IEC 60068-2-30 (Test Db, Unpackaged Damp Heat)	5...95% noncondensing
Shock, operating IEC 60068-2-27 (Test Ea, Unpackaged Shock)	15 g
Shock, nonoperating IEC 60068-2-27 (Test Ea, Unpackaged Shock)	30 g
Vibration IEC 60068-2-6 (Test Fc, Operating)	0.5 g @ 10...500 Hz
Emissions CISPR 11 (IEC 61000-6-4)	Class A
ESD Immunity IEC 61000-4-2	6 kV contact discharge 8 kV air discharge
Conducted RF immunity IEC 61000-4-6	10 V rms with 1 kHz sine-wave 80% AM from 150 kHz...80 MHz
Radiated RF immunity IEC 61000-4-3	10 V/m with 1 kHz sine-wave 80% AM from 80...2000 MHz 10 V/m with 200 Hz 50% Pulse 100% AM @ 900 MHz 10 V/m with 200 Hz 50% Pulse 100% AM @ 1890 MHz 3 V/m with 1 kHz sine-wave 80% AM from 2000...2700 MHz
EFT/B immunity IEC 61000-4-4	±4 kV at 5 kHz on power ports ±3 kV at 5 kHz on Ethernet and FF ports
Surge Transient immunity IEC 61000-4-5	±1 kV line-line (DM) and ±2 kV line-earth (CM) on power ports ±1 kV line-earth (CM) on ControlNet ports ±2 kV line-earth (CM) on Ethernet and FF ports

## Certifications - 1788-EN2FFR, 1788-CN2FFR

Certification (when product is marked) <sup>(1)</sup>	1788-EN2FFR, 1788-CN2FFR
c-UL-us	UL Listed Industrial Control Equipment, certified for US and Canada. See UL File E320594. UL Listed for Class I, Division 2 Group A,B,C,D Hazardous Locations, certified for U.S. and Canada. See UL File E320595.
CE	European Union 2004/108/EC EMC Directive, compliant with: <ul style="list-style-type: none"> <li>EN 61326-1: Meas./Control/Lab., Industrial Requirements</li> <li>EN 61000-6-2: Industrial Immunity</li> <li>EN 61000-6-4: Industrial Emissions</li> <li>EN 61131-2: Programmable Controllers (Clause 8, Zone A and B)</li> </ul>
RCM	Australian Radiocommunications Act, compliant with: <ul style="list-style-type: none"> <li>EN 61000-6-4; Industrial Emissions</li> </ul>
Ex	European Union 94/9/EC ATEX Directive, compliant with: <ul style="list-style-type: none"> <li>EN 60079-15; Potentially Explosive Atmospheres, Protection "n"</li> <li>EN 60079-0; General Requirements II 3 G Ex nA IIC T4 Gc X</li> </ul>
KC	Korean Registration of Broadcasting and Communications Equipment, compliant with: <ul style="list-style-type: none"> <li>Article 58-2 of Radio Waves Act, Clause 3</li> </ul>
EtherNet /IP	ODVA conformance tested to EtherNet/IP specifications
FF	Foundation Fieldbus Test Campaign Number: CT0152FF

(1) See the Product Certification link at <http://www.ab.com> for declarations of conformity, certificates, and other certification details.

## FOUNDATION Fieldbus Junction Boxes

The 1788-FB4R and 1788-FB6 junction boxes provide connections to FOUNDATION Fieldbus networks.

### Technical Specifications - 1788-FB4R, 1788-FB6

Attribute	1788-FB4R	1788-FB6
Power requirements	Input: 12...32V DC, 0.5 A, Class 2/SELV Trunk output: 12...32V DC, 0.36 A, resistive only Drop output: 12...32V DC, 40 mA, resistive only	Input: 12...32V DC, 0.5 A, Class 2/SELV Trunk output: 12...32V DC, 0.48 A, resistive only Drop output: 12...32V DC, 40 mA, resistive only
Power consumption	40 mA at 24 V max.	
Isolation voltage	No isolation between communication channels	
Conductor temperature rating	> 82 °C (180 °F)	
Terminal torque	0.5...0.6 N•m (4.4...5.3 lb•in)	
Wire size	DC power and Foundation Fieldbus connections: 0.205...0.823 mm <sup>2</sup> (24...18 AWG) solid or stranded copper wire rated at 82 °C (180 °F) or greater 1.2 mm (3/64 in.) insulation max	
Wiring category <sup>(1)</sup>	2 - on communication ports	
Enclosure type rating	None (open-style)	
North American temperature code	T4	
IEC temperature code	T4	

(1) Use this Conductor Category information for planning conductor routing. Refer to Industrial Automation Wiring and Grounding Guidelines, publication [1770-4.1](#).

## Environmental Specifications - 1788-FB4R, 1788-FB6

Attribute	1788-FB4R, 1788-FB6
Temperature, operating IEC 60068-2-1 (Test Ad, Operating Cold), IEC 60068-2-2 (Test Bd, Operating Dry Heat), IEC 60068-2-14 (Test Nb, Operating Thermal Shock)	0...60 °C (32...140 °F)
Temperature, surrounding air, max.	60 °C (140 °F)
Temperature, nonoperating IEC 60068-2-1 (Test Ab, Unpackaged Nonoperating Cold), IEC 60068-2-2 (Test Bb, Unpackaged Nonoperating Dry Heat), IEC 60068-2-14 (Test Na, Unpackaged Nonoperating Thermal Shock)	0...60 °C (32...140 °F)
Relative humidity IEC 60068-2-30 (Test Db, Unpackaged Damp Heat)	5...95% noncondensing
Shock, operating IEC 60068-2-27 (Test Ea, Unpackaged Shock)	15 g
Shock, nonoperating IEC 60068-2-27 (Test Ea, Unpackaged Shock)	30 g
Vibration IEC 60068-2-6 (Test Fc, Operating)	0.5 g @ 10...500 Hz
Emissions CISPR 11 (IEC 61000-6-4)	Class A
ESD immunity IEC 61000-4-2	6 kV contact discharge 8 kV air discharge
Conducted RF immunity IEC 61000-4-6	10 V rms with 1 kHz sine-wave 80% AM from 150 kHz...80 MHz
Radiated RF immunity IEC 61000-4-3	10 V/m with 1 kHz sine-wave 80% AM from 80...2000 MHz 10 V/m with 200 Hz 50% Pulse 100% AM @ 900 MHz 10 V/m with 200 Hz 50% Pulse 100% AM @ 1890 MHz 3 V/m with 1 kHz sine-wave 80% AM from 2000...2700 MHz
EFT/B immunity IEC 61000-4-4	±3 kV at 5 kHz on communication ports
Surge Transient immunity IEC 61000-4-5	±2 kV line-earth (CM) on communication ports

## Certifications - 1788-FB4R, 1788-FB6

Certification (when product is marked) <sup>(1)</sup>	1788-FB4R, 1788-FB6
c-UR-us	UL Recognized Component Industrial Control Equipment, certified for US and Canada. See UL File E320594. UL Recognized Component Industrial Control Equipment for Class I, Division 2 Group A,B,C,D Hazardous Locations, certified for US and Canada. See UL File E320595.
CE	European Union 2004/108/EC EMC Directive, compliant with: <ul style="list-style-type: none"> <li>• EN 61326-1: Meas./Control/Lab., Industrial Requirements</li> <li>• EN 61000-6-2: Industrial Immunity</li> <li>• EN 61000-6-4: Industrial Emissions</li> <li>• EN 61131-2: Programmable Controllers (Clause 8, Zone A and B)</li> </ul>
RCM	Australian Radiocommunications Act, compliant with: <ul style="list-style-type: none"> <li>• EN 61000-6-4; Industrial Emissions</li> </ul>
Ex	European Union 94/9/EC ATEX Directive, compliant with: <ul style="list-style-type: none"> <li>• EN 60079-15; Potentially Explosive Atmospheres, Protection "n"</li> <li>• EN 60079-0; General Requirements II 3 G Ex nA IIC T4 Gc X</li> </ul>
KC	Korean Registration of Broadcasting and Communications Equipment, compliant with: <ul style="list-style-type: none"> <li>• Article 58-2 of Radio Waves Act, Clause 3</li> </ul>

(1) See the Product Certification link at <http://www.ab.com> for declarations of conformity, certificates, and other certification details.

## Linking Devices to Profibus PA Networks

The 1788-EN2PAR linking device provides a gateway between EtherNet/IP and Profibus PA networks.

The 1788-CN2PAR linking device provides a gateway between ControlNet and Profibus PA networks.

### Technical Specifications - 1788-EN2PAR, 1788-CN2PAR

Attribute	1788-EN2PAR, 1788-CN2PAR
Power requirements	Input: 24...32V DC, 0.75 A, Class 2/SELV PA: 0.5 A @ 24V DC single trunk; 0.4 A @ 24V DC dual trunk Power is connected to the linking device by using the 4-way Phoenix connector.
Power consumption	260 mA at 24 V (with no field devices attached)
Power dissipation	12.24 W at 24V DC
Isolation voltage	30V (continuous), basic insulation type, network channels to power, and network channels to network channels. No isolation between redundant network channels. Type tested at 500V DC for 60 s.
Ethernet conductors	CAT5 STP/UTP
Terminal torque	DC Power connections: 0.22...0.25 N•m (2...2.2 lb•in) Profibus PA connections: 0.5...0.6 N•m (4.4...5.3 lb•in)
Wire size	DC power and Profibus PA connections: 0.205...0.823 mm <sup>2</sup> (24...18 AWG) solid or stranded copper wire rated at 82 °C (180 °F) or greater 1.2 mm (3/64 in.) insulation max
Wiring category <sup>(1)</sup>	1 - on power ports 2 - on ControlNet, Ethernet, and Foundation Fieldbus ports
Enclosure type rating	None (open-style)
North American temperature code	T4
IEC temperature code	T4

(1) Use this Conductor Category information for planning conductor routing. Refer to Industrial Automation Wiring and Grounding Guidelines, publication [1770-4.1](#).

## Environmental Specifications - 1788-EN2PAR, 1788-CN2PAR

Attribute	1788-EN2PAR, 1788-CN2PAR
Temperature, operating IEC 60068-2-1 (Test Ad, Operating Cold), IEC 60068-2-2 (Test Bd, Operating Dry Heat), IEC 60068-2-14 (Test Nb, Operating Thermal Shock)	0...60 °C (32...140 °F)
Temperature, surrounding air, max.	60 °C (140 °F)
Temperature, nonoperating IEC 60068-2-1 (Test Ab, Unpackaged Nonoperating Cold), IEC 60068-2-2 (Test Bb, Unpackaged Nonoperating Dry Heat), IEC 60068-2-14 (Test Na, Unpackaged Nonoperating Thermal Shock)	0...60 °C (32...140 °F)
Relative humidity IEC 60068-2-30 (Test Db, Unpackaged Damp Heat)	5...95% noncondensing
Shock, operating IEC 60068-2-27 (Test Ea, Unpackaged Shock)	15 g
Shock, nonoperating IEC 60068-2-27 (Test Ea, Unpackaged Shock)	30 g
Vibration IEC 60068-2-6 (Test Fc, Operating)	0.5 g @ 10...500 Hz
Emissions CISPR 11 (IEC 61000-6-4)	Class A
ESD immunity IEC 61000-4-2	6 kV contact discharge 8 kV air discharge
Conducted RF immunity IEC 61000-4-6	10 V rms with 1 kHz sine-wave 80% AM from 150 kHz...80 MHz
Radiated RF immunity IEC 61000-4-3	10 V/m with 1 kHz sine-wave 80% AM from 80...2000 MHz 10 V/m with 200 Hz 50% Pulse 100% AM @ 900 MHz 10 V/m with 200 Hz 50% Pulse 100% AM @ 1890 MHz 3 V/m with 1 kHz sine-wave 80% AM from 2000...2700 MHz
EFT/B immunity IEC 61000-4-4	±4 kV at 5 kHz on power ports ±3 kV at 5 kHz on Ethernet and FF ports
Surge Transient immunity IEC 61000-4-5	±1 kV line-line (DM) and ±2 kV line-earth (CM) on power ports ±1 kV line-earth (CM) on ControlNet ports ±2 kV line-earth (CM) on Ethernet and FF ports

## Certifications - 1788-EN2PAR, 1788-CN2PAR

Certification (when product is marked) <sup>(1)</sup>	1788-EN2PAR, 1788-CN2PAR
c-UL-us	UL Listed Industrial Control Equipment, certified for US and Canada. See UL File E320594. UL Listed for Class I, Division 2 Group A,B,C,D Hazardous Locations, certified for U.S. and Canada. See UL File E320595.
CE	European Union 2004/108/EC EMC Directive, compliant with: <ul style="list-style-type: none"> <li>EN 61326-1: Meas./Control/Lab., Industrial Requirements</li> <li>EN 61000-6-2: Industrial Immunity</li> <li>EN 61000-6-4: Industrial Emissions</li> <li>EN 61131-2: Programmable Controllers (Clause 8, Zone A and B)</li> </ul>
RCM	Australian Radiocommunications Act, compliant with: <ul style="list-style-type: none"> <li>EN 61000-6-4: Industrial Emissions</li> </ul>
Ex	European Union 94/9/EC ATEX Directive, compliant with: <ul style="list-style-type: none"> <li>EN 60079-15; Potentially Explosive Atmospheres, Protection "n"</li> <li>EN 60079-0; General Requirements II 3 G Ex nA IIC T4 Gc X</li> </ul>
KC	Korean Registration of Broadcasting and Communications Equipment, compliant with: <ul style="list-style-type: none"> <li>Article 58-2 of Radio Waves Act, Clause 3</li> </ul>
EtherNet /IP	ODVA conformance tested to EtherNet/IP specifications

(1) See the Product Certification link at <http://www.ab.com> for declarations of conformity, certificates, and other certification details.

## Additional Resources

These documents contain additional information concerning related products from Rockwell Automation.

Resource	Description
EtherNet/IP to DeviceNet Linking Device User Manual, publication <a href="#">1788-UM059</a>	Provides information on installing and using the 1788-EN2DNR linking device.
ControlNet-to-DeviceNet Linking Device Installation Instructions, publication <a href="#">1788-IN052</a>	Provides information on installing and using the 1788-CN2DN linking device.
EtherNet/IP and ControlNet to FOUNDATION Fieldbus Linking Devices User Manual, publication <a href="#">1788-UM057</a>	Provides information on the installation and operation of the 1788-EN2FFR and 1788-CN2FFR linking devices.
EtherNet/IP and ControlNet to PROFIBUS PA Linking Device User Manual, publication <a href="#">1788-UM058</a>	Provides information on the installation and operation of the 1788-EN2PAR and 1788-CN2PAR linking devices.
Industrial Automation Wiring and Grounding Guidelines, publication <a href="#">1770-4.1</a>	Provides general guidelines for installing a Rockwell Automation industrial system.
Product Certifications website, <a href="http://www.ab.com">http://www.ab.com</a>	Provides declarations of conformity, certificates, and other certification details.

You can view or download publications at <http://www.rockwellautomation.com/literature/>. To order paper copies of technical documentation, contact your local Allen-Bradley distributor or Rockwell Automation sales representative.



**Notes:**

## Important User Information

Read this document and the documents listed in the additional resources section about installation, configuration, and operation of this equipment before you install, configure, operate, or maintain this product. Users are required to familiarize themselves with installation and wiring instructions in addition to requirements of all applicable codes, laws, and standards.

Activities including installation, adjustments, putting into service, use, assembly, disassembly, and maintenance are required to be carried out by suitably trained personnel in accordance with applicable code of practice.

If this equipment is used in a manner not specified by the manufacturer, the protection provided by the equipment may be impaired.

In no event will Rockwell Automation, Inc. be responsible or liable for indirect or consequential damages resulting from the use or application of this equipment.

The examples and diagrams in this manual are included solely for illustrative purposes. Because of the many variables and requirements associated with any particular installation, Rockwell Automation, Inc. cannot assume responsibility or liability for actual use based on the examples and diagrams.

No patent liability is assumed by Rockwell Automation, Inc. with respect to use of information, circuits, equipment, or software described in this manual.

Reproduction of the contents of this manual, in whole or in part, without written permission of Rockwell Automation, Inc., is prohibited.

## Documentation Feedback

Your comments will help us serve your documentation needs better. If you have any suggestions on how to improve this document, complete this form, publication [RA-DU002](#), available at <http://www.rockwellautomation.com/literature/>.

Rockwell Automation maintains current product environmental information on its website at <http://www.rockwellautomation.com/rockwellautomation/about-us/sustainability-ethics/product-environmental-compliance.page>.

Allen-Bradley, Rockwell Software, Rockwell Automation, and LISTEN. THINK. SOLVE are trademarks of Rockwell Automation, Inc. Trademarks not belonging to Rockwell Automation are property of their respective companies.

Rockwell Otomasyon Ticaret A.Ş., Kar Plaza İş Merkezi E Blok Kat:6 34752 İçerenköy, İstanbul, Tel: +90 (216) 5698400

**[www.rockwellautomation.com](http://www.rockwellautomation.com)**

---

### Power, Control and Information Solutions Headquarters

Americas: Rockwell Automation, 1201 South Second Street, Milwaukee, WI 53204-2496 USA, Tel: (1) 414.382.2000, Fax: (1) 414.382.4444  
Europe/Middle East/Africa: Rockwell Automation NV, Pegasus Park, De Kleetlaan 12a, 1831 Diegem, Belgium, Tel: (32) 2 663 0600, Fax: (32) 2 663 0640  
Asia Pacific: Rockwell Automation, Level 14, Core F, Cyberport 3, 100 Cyberport Road, Hong Kong, Tel: (852) 2887 4788, Fax: (852) 2508 1846